

POLLUTION MONITORING DATA

Licensee: Central Coast Council, PO Box 20 Wyong NSW 2259

EPL No. 1942 – Bateau Bay Sewage Treatment System

Location of Pollution Monitoring Point: Inlet channel to the chlorine contact tank

Licence Period: 1 January 2024 – 31 December 2024

Publishing Date: 23 April 2024

COMPLIANCE STATUS

Results obtained for licence period are within annual concentration limits.

	Biochemical Oxygen Demand (BOD) (mg/L)	Oil and Grease (O&G) (mg/L)	pH	Total Suspended Solids (TSS)	Ammonia (mg/L)
--	---	--------------------------------------	----	------------------------------------	-------------------

License Concentration Limits

100 percentile	30	10	6.5 - 8.5	50	30
-----------------------	----	----	-----------	----	----

Pollution Monitoring Data Summary (provided at the end of reporting period)

100 percentile	-	-	-	-	-
-----------------------	---	---	---	---	---

Collected	Obtained	Published	BOD (mg/L)	O&G (mg/L)	pH	TSS (mg/L)	Ammonia
09/01/2024	19/01/2024	24/01/2024	6	<5	7.6	2	19.1
21/01/2024	02/02/2024	15/02/2024	6	<5	7.1	<2	2.3
02/02/2024	14/02/2024	19/02/2024	5	<5	7.2	7	5.6
14/02/2024	26/02/2024	04/03/2024	9	<5	7.1	17	6.2
26/02/2024	12/03/2024	17/03/2024	6	<5	7.1	6	2.3
09/03/2024	25/03/2024	30/03/2024	3	<5	7.1	5	3.3
21/03/2024	04/04/2024	09/04/2024	5	<5	6.9	8	3.0
02/04/2024	11/04/2024	16/04/2024	11	<5	7.5	4	16.5

< : Where this symbol is shown, the result is below the limit at which the parameter can be accurately detected and reported.
n/a means not available.
Where results are below the laboratory detection limits (e.g. <2) half the value of the detection limit will be used for calculation purposes when all required data has been obtained. Where 50% or more of the sample results for a particular pollutant are below the detection limit, zero will be used for calculation purposes. This methodology is consistent with that outlined in the EPA's Load Calculation Protocol (June 2009) and will be applied when all required data for the licence period has been obtained.

POLLUTION MONITORING DATA

Licensee: Central Coast Council, PO Box 20 Wyong NSW 2259

EPL No. 1942 – Bateau Bay Sewage Treatment System

Location of Pollution Monitoring Point: Composite sampling point prior to outlet to sand dune disposal area

Licence Period: 1 January 2023 – 31 December 2024

Publishing Date: 23 April 2024

COMPLIANCE STATUS

Licence Monitoring Frequency for below pollutant is twice per year. The licence does not prescribe concentration limits for these pollutants.

	Aldrin	Arsenic	Cadmium	Chlordane (cis & trans)	Chromium	Copper	Dieldrin	Endosulfan	Endrin	Heptachlor	Heptachlor epoxide	Hexachlorobenzene	Lead	Mercury	Methoxychlor	Nickel	Selenium	Silver	Zinc	alpha-BHC	beta-BHC	gamma-BHC (lindane)	p,p-DDD	p,p-DDE	p,p-DDT	PCBs
Unit	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
No. Samples Collected	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
Minimum value																										
Mean value																										
Median value																										
Maximum value																										
Limit of laboratory detection	0.01	0.2	0.1	0.01	0.2	0.5	0.01	0.01	0.01	0.01	0.01	0.01	0.1	0.3	0.01	0.2	0.2	0.1	1	0.01	0.01	0.01	0.01	0.01	0.01	0.1

POLLUTION MONITORING DATA RESULTS

Collected	Obtained	Published	Aldrin	Arsenic	Cadmium	Chlordane (cis & trans)	Chromium	Copper	Dieldrin	Endosulfan	Endrin	Heptachlor	Heptachlor epoxide	Hexachlorobenzene	Lead	Mercury	Methoxychlor	Nickel	Selenium	Silver	Zinc	alpha-BHC	beta-BHC	gamma-BHC (lindane)	p,p-DDD	p,p-DDE	p,p-DDT	PCBs	
21/01/2024	02/02/2024	15/02/2024	<0.01	1.6	<0.1	<0.01	0.7	12.9	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	0.1	<0.3	<0.01	1.6	<0.2	0.2	39	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.1
02/04/2024	11/04/2024	16/04/2024	<0.01	0.5	<0.1	<0.01	0.6	11.7	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	0.2	<0.3	<0.01	1.9	0.2	0.3	29	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.1

<: Where this symbol is shown, the result is below the level at which the parameter can be routinely tested and reported.

n/a means not available.

Where results are below the laboratory detection limits (e.g. <2) half the value of the detection limit will be used for calculation purposes when all required data has been obtained. Where 50% or more of the sample results for a particular pollutant are below the detection limit, zero will be used for calculation purposes. This methodology is consistent with that outlined in the EPA’s Load Calculation Protocol (June 2009) and will be applied when all required data for the licence period has been obtained.

EPL No 1942 - Summary of non-compliant data				
Date	Parameter	Result	Cause	Action taken
5 April 2024	Flow (greater than 36,000 kL)	42,263 kL	Stormwater Inflow	Management of inflow from STP catchment
6 April 2024	Flow (greater than 36,000 kL)	38,434 kL	Stormwater Inflow	Management of inflow from STP catchment