





**POLLUTION MONITORING DATA**

**Licensee:** Central Coast Council, PO Box 20 Wyong NSW 2259

**EPL No. 1942** – Bateau Bay Sewage Treatment System

**Location of Pollution Monitoring Point:** Composite sampling point prior to outlet to sand dune disposal area

**Licence Period:** 1 January 2023 – 31 December 2024

**Publishing Date:** 1 May 2024

**COMPLIANCE STATUS**

Licence Monitoring Frequency for below pollutant is twice per year. The licence does not prescribe concentration limits for these pollutants.

	Aldrin	Arsenic	Cadmium	Chlordane (cis & trans)	Chromium	Copper	Dieldrin	Endosulfan	Endrin	Heptachlor	Heptachlor epoxide	Hexachlorobenzene	Lead	Mercury	Methoxychlor	Nickel	Selenium	Silver	Zinc	alpha-BHC	beta-BHC	gamma-BHC (lindane)	p,p-DDD	p,p-DDE	p,p-DDT	PCBs
<b>Unit</b>	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
<b>No. Samples Collected</b>	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
<b>Minimum value</b>																										
<b>Mean value</b>																										
<b>Median value</b>																										
<b>Maximum value</b>																										
<b>Limit of laboratory detection</b>	0.01	0.2	0.1	0.01	0.2	0.5	0.01	0.01	0.01	0.01	0.01	0.01	0.1	0.3	0.01	0.2	0.2	0.1	1	0.01	0.01	0.01	0.01	0.01	0.01	0.1

**POLLUTION MONITORING DATA RESULTS**

Collected	Obtained	Published	Aldrin	Arsenic	Cadmium	Chlordane (cis & trans)	Chromium	Copper	Dieldrin	Endosulfan	Endrin	Heptachlor	Heptachlor epoxide	Hexachlorobenzene	Lead	Mercury	Methoxychlor	Nickel	Selenium	Silver	Zinc	alpha-BHC	beta-BHC	gamma-BHC (lindane)	p,p-DDD	p,p-DDE	p,p-DDT	PCBs	
21/01/2024	02/02/2024	15/02/2024	<0.01	1.6	<0.1	<0.01	0.7	12.9	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	0.1	<0.3	<0.01	1.6	<0.2	0.2	39	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.1
02/04/2024	11/04/2024	16/04/2024	<0.01	0.5	<0.1	<0.01	0.6	11.7	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	0.2	<0.3	<0.01	1.9	0.2	0.3	29	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.1

<: Where this symbol is shown, the result is below the level at which the parameter can be routinely tested and reported.

n/a means not available.

Where results are below the laboratory detection limits (e.g. <2) half the value of the detection limit will be used for calculation purposes when all required data has been obtained. Where 50% or more of the sample results for a particular pollutant are below the detection limit, zero will be used for calculation purposes. This methodology is consistent with that outlined in the EPA's Load Calculation Protocol (June 2009) and will be applied when all required data for the licence period has been obtained.





EPL No 1942 - Summary of non-compliant data				
Date	Parameter	Result	Cause	Action taken
5 April 2024	Flow (greater than 36,000 kL)	42,263 kL	Stormwater Inflow	Management of inflow from STP catchment
6 April 2024	Flow (greater than 36,000 kL)	38,434 kL	Stormwater Inflow	Management of inflow from STP catchment